

## Stage 2 Disinfectants and Disinfection Byproducts Rule Reporting Spreadsheet

**Water System:** DC Water  
**PWSID:** DC0000002  
**Report Period:** 2nd Quarter 2019

- Steps: 1. Use data from three previous quarters  
 2. Enter sample date and results for current quarter of monitoring in the blue column.  
 3. Summarize results for the quarter. The number of samples should include the number of any repeat samples.

**Total Trihalomethanes (TTHM)**  
 Reported as mg/L or ppm

Number of TTHM samples taken per quarter: 12  
 Operational Evaluation Levels exceeded (Yes/No): No  
 TTHM MCL violations: No

		Three Most Recent Quarters of Sampling Results*			Current Quarter		
Scheduled Sample Month		Aug 2018	Nov 2018	Feb 2019	May 2019		
Actual Sample Date:							
Location ID	Location Name					Operational Evaluation Level (OEL)	Locational Running Annual Average (LRAA)
1H-9	1700 EAST CAPITOL ST NE	0.075	0.033	0.014	0.067	0.045	0.047
1H-23/1H-24	407 8th St NE	0.073	0.040	0.011	0.048	0.037	0.043
2H-1 BKJV	1731 BUNKER HILL RD NE	0.075	0.035	0.012	0.063	0.043	0.046
2H-27	3101 Rhode Island Ave, NE	0.074	0.040	0.012	0.063	0.045	0.047
3H-4 BKJV	1640 KALMIA RD NW	0.057	0.032	0.014	0.052	0.038	0.039
3H-13	120 KENNEDY ST NW	0.055	0.034	0.012	0.057	0.040	0.040
4H-8	5608 BROAD BRANCH RD NW	0.056	0.025	0.012	0.042	0.030	0.034
A1H-3 BKJV	420 56TH ST NE	0.070	0.037	0.014	0.065	0.045	0.046
A1H-8/A2H-8*	3125 MARTIN LUTHER KING AVE SE	0.071	0.032	0.013	0.047	0.035	0.041
L-24 DBPR	1350 49TH ST NE	0.075	0.035	0.014	0.056	0.040	0.045
L-4	550 WATER ST SW	0.065	0.027	0.013	0.044	0.032	0.037
L-12	5000 OVERLOOK AVE SW	0.071	0.031	0.013	0.047	0.035	0.041
*Note: (a) 1H-24 (Jacob's Coffee House, 401 8th St NE) replaced 1H-23 beginning February 2019 (b) Location ID for A1H-8 (My 3 Sons Barber Shop, 3125 MLK Ave SE) was changed to A2H-8 beginning February 2018, the address remain same						If TTHM OEL is > 0.080, perform Operational Evaluation.	If TTHM LRAA is > 0.080, MCL violation occurred.

**Five Haloacetic Acids (HAA5)**  
 Reported as mg/L or ppm

Number of HAA5 samples taken per quarter: 12  
 Operational Evaluation Levels exceeded (Yes/No): No  
 HAA5 MCL violations: No

		Three Most Recent Quarters of Sampling Results*			Current Quarter		
Scheduled Sample Month		Aug 2018	Nov 2018	Feb 2019	May 2019		
Actual Sample Date:							
Location ID	Location Name					Operational Evaluation Level (OEL)	Locational Running Annual Average (LRAA)
1H-9	1700 EAST CAPITOL ST NE	0.048	0.028	0.009	0.039	0.029	0.031
1H-23/1H-24*	401 8th St NE	0.050	0.030	0.008	0.030	0.025	0.030
2H-1 BKJV	1731 BUNKER HILL RD NE	0.021	0.021	0.008	0.038	0.026	0.022
2H-27	3101 Rhode Island Ave, NE	0.054	0.032	0.009	0.037	0.029	0.033
3H-4 BKJV	1640 KALMIA RD NW	0.005	0.013	0.009	0.035	0.023	0.016
3H-13	120 KENNEDY ST NW	0.049	0.034	0.008	0.038	0.030	0.032
4H-8	5608 BROAD BRANCH RD NW	0.038	0.023	0.009	0.032	0.024	0.025
A1H-3 BKJV	420 56TH ST NE	0.035	0.018	0.009	0.042	0.028	0.026
A1H-8/A2H-8*	3125 MARTIN LUTHER KING AVE SE	0.050	0.031	0.010	0.033	0.027	0.031
L-24 DBPR	1350 49TH ST NE	0.030	0.026	0.010	0.042	0.030	0.027
L-4	550 WATER ST SW	0.050	0.025	0.010	0.034	0.026	0.030
L-12	5000 OVERLOOK AVE SW	0.048	0.029	0.008	0.034	0.026	0.030
*Note: (a) 1H-24 (Jacob's Coffee House, 401 8th St NE) replaced 1H-23 beginning February 2019 (b) Location ID for A1H-8 (My 3 Sons Barber Shop, 3125 MLK Ave SE) was changed to A2H-8 beginning February 2018, the address remain same						If HAA5 OEL is > 0.060, perform Operational Evaluation.	If HAA5 LRAA is > 0.060, MCL violation occurred.